



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
Vadamadurai Cauvery Water Pump House Campus,
Near Vadamadurai Railway Track, Dindigul - 624802.



TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	DWTL/TR/2026/0133-01	Report Issue Date :	25.05.2026	Page No :	1 of 1
Invoice Details:	1060/Dt.19.05.2026 Amt.Rs.1652/-	ULR No : TC1758500000085F			

Client Name & Address	: Kallalagar Vidya Mandir School,				
Contact No / Email Id	: Chellapanayakenpatti Road,				
	: Natham - 624 401.				
	: 8489034490				
Sample / Lab No	: 2026/DGL0133				
Sample Name	: Water - Drinking Water				
Sample Description	: Clear Colorless liquid				
Sample Source	: Reverse Osmosis Water				
Sample Submitted by	: Customer				
Location & Date	: Kallalagar Vidya Mandir School, Natham & 19.05.26				
Sample Container	: Plastic - Good Condition				
Quantity of sample Received	: 2 Litre	Sample Condition on Receipt	:	Good	
Sample Received On	: 19.05.2026	Environmental Condition Temp °C	:	23 - 27 °C	
Test Commenced on	: 20.05.2026	Test Completed on	:	25.05.2026	

S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25°C	--	IS 3025: Part 11: 2022	7.13	6.5-8.5	No Relaxation
2	Total Hardness as CaCO ₃	mg/l.	IS 3025: Part 21: 200 (RA:2023)	190	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	16	200	600
4	Chloride as Cl	mg/L	IS 3025: Part 32: 1988 (RA:2019)	19	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025: (Part 24/Sec 1): 2022 - Turbidity Method	< 5.0	200	400
6	Nitrate as NO ₃	mg/L	IS 3025: (Part 34/Sec-1): 2023 - Screening Method	< 2.0	45	No Relaxation
7	Fluoride as F	mg/L	IS 3025: (Part 60/Sec-1): 2023 - SPADNS Method;	< 0.2	1.0	1.5

Remark : The tested sample conformed to IS: 10500:2012 (RA: 2023) Drinking water Acceptable Limit / Permissible Limit specification with respect to above tested parameters.

---End of the Report---


Reviewed and Authorised by
J. Mohamed Harith - Assistant Engineer

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

**Vadamadurai Cauvery Water Pump House Campus,
Near Vadamadurai Railway Track, Dindigul - 624802**

TEST REPORT


Doc.No: DWTL/FORM/7.8/01

Report No:	DWTL/TR/2026/ 0133-02	Report Issue Date :	25.05.2026	Page No : 1 of 1
Invoice Details:	1060/Dt.19.05.2026 Amt.Rs.1652/-			

Client Name & Address Contact No / Email Id	: Kallalagar Vidya Mandir School, Chellapanayakenpatti Road, Natham – 624 401. 8489034490					
Sample / Lab No	: 2026/DGL0133					
Sample Name	: Water - Drinking Water					
Sample Description	: Clear Colorless liquid					
Sample Source	: Reverse Osmosis Water					
Sample Submitted by	: Customer					
Location & Date	: Kallalagar Vidya Mandir School, Natham & 19.05.26					
Sample Container	: Plastic – Good Condition					
Quantity of sample Received	: 2 Litre	Sample Condition on Receipt	: Good			
Sample Received On	: 19.05.2026	Environmental Condition Temp °C	: 23 – 27 °C			
Test Commenced on	: 20.05.2026	Test Completed on	: 25.05.2026			
S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	--	Visual	Clear	--	--
2	Odour	--	IS 3025: Part 5: 2018	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025: Part 10: 2023	< 0.5	1	5
4	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	270	500	2000
5	EC @ 25°C	µS/cm	IS 3025: Part 14: 2013	491	--	--
6	Iron as Fe mg/L	mg/L	IS 3025 (Part 53) : 2024	< 0.1	0.3	No Relaxation
7	Residual Chlorine	mg/L	IS 3025 (Part 26) : 2007	0	0.2	1.0
Bacteriological Examination						
1	Fecal coliform	CFU / 100 ml	IS 15185 : 2016- RA : 2021	0	Absent/100 mL	

Remark: The tested sample conformed to IS : 10500:2012(RA:2023)drinking water specification with respect to above tested parameter.

---End of the report---


Reviewed and Authorised by
J. Mohamed Harith - Assistant Engineer

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

ANNEXURE C
PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE


No: 01/2026

Date: 05/06/2026

It is certified that an inspection team headed by A. GIANESAN
Name & Address of the School) from BLOCK HEALTH SUPERVISOR, GPHC
inspected KALLALAGAR VIDYA MANDIR SCHOOL, the ULUPPAGUDI,
CHELLAPPANAYAKKEN PATTI ROAD, NATHAM-624401
(Name & Address of the School) on 04/06/2026 (date of inspection) and on the
basis of Water Test Report (ATTACHED) bearing No. DWT/ TR /2026/0133-01/02
DATED 25-05-2026 of DISTRICT WATER TESTING LAB, TWARD
(PHED LAB)
certified that the KALLALAGAR VIDYA MANDIR SCHOOL, NATHAM (Name

of the school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central / State / U.T. Govt.

This certificate is valid till ONE YEAR FROM DATE OF ISSUE

Signature with Seal: 
Name: BLOCK HEALTH SUPERVISOR
G.P.H.C. ULUPPAGUDI,
Designation: NATHAM BLOCK,
DINDIGUL DIST - 624401.
Name & Address of the Office / Department: _____

To KALLALAGAR VIDYA MANDIR SCHOOL,
CHELLAPPANAYAKKEN PATTI ROAD, NATHAM
Name & Address of the Institution 624401

Note: The certificate is to be issued by authorized officer / PHED Lab / Local Bodies.



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

**(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated
23.09.2024 on the basis of affidavit by the applicant)**

Certificate Number : TN00126DGL35150

Issued Date : 18-05-2026

Organization Type : Educational Institutions

Expiry Date : 17-05-2027

Name of the Organization : KALLALAGAR VIDYA MANDIR SCHOOL

Address : CHELLAPPANAYAKKANPATTI ROAD, NATHAM

TALUKA, DINDIGUL DISTRICT

I, **KALLALAGAR SELVAM** owner/manager of the **KALLALAGAR VIDYA MANDIR SCHOOL** functioning as **Educational Institutions** located at **Sellappanaickenpatty** in **Dindigul** district hereby declare that

- This Self-Declared Sanitation certificate is valid from **18-05-2026** to **17-05-2027** and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate **129** people/pupils and has **26** urinals and **40** toilets which is proportionate to the number of users as per government norms.
- **6** Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.



Signature of the Owner/Manager



(அ) TN00126DGL35150 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பார்ப்பதற்கு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00126DGL35150 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.